



NO.1123020479

检 测 报 告

Test Report

样品名称： 锂离子电池组 V5° 51.2V 100Ah 5.12kWh

Name of Sample: Lithium ion Battery Pack V5° 51.2V 100Ah 5.12kWh

委托单位： 上海派智能源股份有限公司

Consignor: Shanghai PYTES Energy Co., Ltd.



上海化工院检测有限公司

Shanghai Institute of Chemical Industry Testing Co., Ltd.

声 明

Statement

1. 检测报告无本实验室公章（或检验检测专用章）无效。
The test report is invalid if it is not affixed the official seal of the laboratory to it.
2. 复制检测报告未重新加盖本实验室公章（或检验检测专用章）无效。
Copies of the test report without the official seal of the laboratory are invalid.
3. 检测报告无编制、审核、批准人签字无效。
The test report is invalid without the signatures of compiler, checker and approver.
4. 检测报告涂改无效。
The test report is invalid if it is blotted out.
5. 未经本实验室书面批准，不得部分复制检测报告。
It is forbidden to copy the test report partially without the written approval of the laboratory.
6. 送样委托检测结果，仅对所送样品有效。
The conclusion of the consignment test is only valid for the provided sample.
7. 本检测报告以中文为准，英文文本（如有）仅为译文，两者发生冲突时，应以中文文本为准。
The test report has been drafted in Chinese and translated into English (if exist) for convenience only. In the event of discrepancy, the Chinese version shall prevail.
8. 除另有说明，检测检验类别都是指委托分析。
Unless noted otherwise, the test type is consignment test.

地址：上海市云岭东路 345 号

Address: No.345 East Yunling Road, Shanghai

邮政编码(Post Code): 200062

电话(Tel): (021) 31765555

传真(Fax): (021) 31015117

网址 (web site): www.ghs.cn

电子信箱 (E-mail): center@ghs.cn

上海化工院检测有限公司
检测报告
Shanghai Institute of Chemical Industry
Testing Co., Ltd. Test Report

NO. 1123020479

1/11

样品名称 Name of Sample	中文 Chinese	锂离子电池组 V5° 51.2V 100Ah 5.12kWh	
	英文 English	Lithium ion Battery Pack V5° 51.2V 100Ah 5.12kWh	
样品编号 Sample No.	1123020479		
委托单位 Consignor	上海派智能能源股份有限公司 Shanghai PYTES Energy Co., Ltd.		
生产单位 Manufacturer	上海派智能能源股份有限公司 Shanghai PYTES Energy Co., Ltd.		
检测方法 Test method	联合国《试验和标准手册》 ST/SG/AC.10/11/Rev.7 38.3 UN Manual of Tests and Criteria ST/SG/AC.10/11/Rev.7 Section 38.3		
判定标准 Criterion	联合国《试验和标准手册》 ST/SG/AC.10/11/Rev.7 38.3 UN Manual of Tests and Criteria ST/SG/AC.10/11/Rev.7 Section 38.3		
样品外观 Appearance	银色金属外壳 Silvery Metal shell		
样品接受日期 Accepted Date	2023-02-21	检测起造日期 Test Date	2023-03-01 ~ 2023-03-31
检测项目 Test Items	高度模拟;热测试;振动;冲击;外短路;挤压;过充电;强制放电 Altitude simulation, Thermal test, Vibration, Shock, External short circuit, Crush, Overcharge, Forced discharge		
检测结论 Conclusion	经检测,该样品符合联合国《试验和标准手册》ST/SG/AC.10/11/Rev.7 38.3标准要求。 The sample has passed the test items of UN Manual of Tests and Criteria ST/SG/AC.10/11/Rev.7 Section 38.3 生效日期(Date): 2023-04-04		
备注 Comment	可充电锂电池组。 Rechargeable Lithium Battery. 全部项目测试地点为江苏省昆山市康浦路3号。 All tests were tested in No.3, Kangpu Road, Kunshan, Suzhou, Jiangsu, China.		
委托单位地址 Consignor Address			邮政编码 Post Code

批准
Approver:
职务
Title:

许莹

审核
Checker:

高子翔

编制
Compiler:

李强

电化学测试部部长(Head of Electrochemical Testing Department)



上海化工院检测有限公司

检测报告

Shanghai Institute of Chemical Industry
Testing Co., Ltd. Test Report

NO. 1123020479

2/11


序号 No.	检测项目名称 Name of Test Items	标准要求或标准条款号 Standard requirement or The Clause Number of Standard	检测结果 Test Result	本项结论 Conclusion	备注 Remark	
1	高度模拟 Altitude simulation	联合国《试验和标准手册》ST/SG/AC.10/11/Rev.7 38.3 试验T.1 UN Manual of Tests and Criteria ST/SG/AC.10/11/Rev.7 Section 38.3 Test T.1	见附表 1 See Appendix 1	合格 Passed	/	
2	热测试 Thermal test	联合国《试验和标准手册》ST/SG/AC.10/11/Rev.7 38.3 试验T.2 UN Manual of Tests and Criteria ST/SG/AC.10/11/Rev.7 Section 38.3 Test T.2	见附表 2 See Appendix 2	合格 Passed	/	
3	振动 Vibration	联合国《试验和标准手册》ST/SG/AC.10/11/Rev.7 38.3 试验T.3 UN Manual of Tests and Criteria ST/SG/AC.10/11/Rev.7 Section 38.3 Test T.3	见附表 3 See Appendix 3	合格 Passed	/	
4	冲击 Shock	联合国《试验和标准手册》ST/SG/AC.10/11/Rev.7 38.3 试验T.4 UN Manual of Tests and Criteria ST/SG/AC.10/11/Rev.7 Section 38.3 Test T.4	见附表 4 See Appendix 4	合格 Passed	/	
5	外短路 External short circuit	联合国《试验和标准手册》ST/SG/AC.10/11/Rev.7 38.3 试验T.5 UN Manual of Tests and Criteria ST/SG/AC.10/11/Rev.7 Section 38.3 Test T.5	见附表 5 See Appendix 5	合格 Passed	/	
6	挤压 Crush	联合国《试验和标准手册》ST/SG/AC.10/11/Rev.7 38.3 试验T.6 UN Manual of Tests and Criteria ST/SG/AC.10/11/Rev.7 Section 38.3 Test T.6	见附表 6 See Appendix 6	合格 Passed	/	
7	过充电 Overcharge	联合国《试验和标准手册》ST/SG/AC.10/11/Rev.7 38.3 试验T.7 UN Manual of Tests and Criteria ST/SG/AC.10/11/Rev.7 Section 38.3 Test T.7	见附表 7 See Appendix 7	合格 Passed	/	
8	强制放电 Forced discharge	联合国《试验和标准手册》ST/SG/AC.10/11/Rev.7 38.3 试验T.8 UN Manual of Tests and Criteria ST/SG/AC.10/11/Rev.7 Section 38.3 Test T.8	见附表 8 See Appendix 8	合格 Passed	/	
检测环境条件 Test Environment Condition		环境温度:20℃-23℃;环境湿度:/% Ambient temperature:20℃-23℃;Ambient humidity:/%				
分包检验情况 Subcontracted Test Condition		检测项目 Test Item	/			
		分包实验室 Subcontracted Laboratory	名称 Name	/	邮编 Post Code	/
			地址 Address	/	电话 Tel	/

上海化工院检测有限公司
 检测报告—附表8
 Shanghai Institute of Chemical Industry
 Testing Co., Ltd. Test Report—Appendix 8


NO. 1123020479

10/11

序号 No.	8	检测项目名称 Name of Test Items	强制放电 Forced discharge
样品编号 Sample No.	样品状态 Sample Status	其他现象 Other Event	
015	1CYC完全放电 1CYC Fully discharged		O
016	1CYC完全放电 1CYC Fully discharged		O
017	1CYC完全放电 1CYC Fully discharged		O
018	1CYC完全放电 1CYC Fully discharged		O
019	1CYC完全放电 1CYC Fully discharged		O
020	1CYC完全放电 1CYC Fully discharged		O
021	1CYC完全放电 1CYC Fully discharged		O
022	1CYC完全放电 1CYC Fully discharged		O
023	1CYC完全放电 1CYC Fully discharged		O
024	1CYC完全放电 1CYC Fully discharged		O
025	25CYC完全放电 25CYC Fully discharged		O
026	25CYC完全放电 25CYC Fully discharged		O
027	25CYC完全放电 25CYC Fully discharged		O
028	25CYC完全放电 25CYC Fully discharged		O
029	25CYC完全放电 25CYC Fully discharged		O
030	25CYC完全放电 25CYC Fully discharged		O
031	25CYC完全放电 25CYC Fully discharged		O
032	25CYC完全放电 25CYC Fully discharged		O
033	25CYC完全放电 25CYC Fully discharged		O
034	25CYC完全放电 25CYC Fully discharged		O
备注：D-解体 F-起火 O-无解体、无起火。 Note: D-Disassembly F-Fire O-No Disassembly & No Fire.			



Pytes	
Battery Model	V5°
Battery Cell Type	Li-ion Battery
Operating Voltage Range	47.5V-57.6V
Nominal Voltage	51.2V
Rated Energy	5.12kWh
Rated Capacity	100Ah
Rated Charge/Discharge Current	75A
Maximum Charge/Discharge Current	100A
Maximum Charge/Discharge Power	5120W
Operating Temperature	0°C-45°C



报告结束



